

CORRIGENDUM

"Supply, installation & commissioning of Roof Top Solar PV Power Panel at UCO Bank Ahmadpur Branch (Add: Main Market Road VPO-Ahmadpur Kasba Dist-Vidisha, M.P.)

With reference to RFP/ Tender Notice issued vide ZO/GAD/2026-27/07 dated 08.04.2026. On 24.04.2026, Prebid meeting for aforesaid tender was conducted at UCO Bank Zonal Office, Bhopal. Following points are the clarifications/ amendments that to be included in the original tender document published on 08.04.2026.

Annexure VIII (Pg 43 & 44)

| S.No. | Item | Description Given | Amendment |
|-------|---------------------|---|---|
| 1 | Solar PV Module | 540-550 Wp ALMM/MNRE approved Bifacial/ topcon Module with Min. Module Efficiency 21.3% IEC & BIS Certified (Manufactured in India) with Annual Degradation Not More Than 0.60% of Make Tata/ Adani/ Waaree/ Rayzon/ Jakson/ Vikram or equivalent | 540-550 Wp ALMM/MNRE (DCR) approved Bifacial/ topcon Module with Min. Module Efficiency 21.3% IEC & BIS Certified (Manufactured in India) with Annual Degradation Not More Than 0.60% of Make Tata/ Adani/ Waaree/ Rayzon/ Jakson/ Vikram or equivalent |
| 2 | Earthing Cable | Earthing Strip 25x3 mm PVC insulated flexible copper Y/G | GI Strip 25x5 or copper wire 10mm |
| 3 | Earthing Protection | 3 m copper welded earthing wit dia 80 mm and 3 meter long. Pit at DC Side: 01 Nos Pit at AC Side: 01 Nos Pit at LA Side: 01 Nos | 3 m copper bonded earthing wit dia 18 mm and 3 meter long. Pit at DC Side: 01 Nos Pit at AC Side: 01 Nos Pit at LA Side: 01 Nos |

• For items used (especially panels & inverter), OEM certification or Authorized Dealer Certificate is mandatory and only those products will be considered/allowed to be installed whose OEM certification or Authorized Dealer Certificate is submitted at time of tender submission.

• Considering the above amendments, the **last date of submission of bid/ offer is extended till 08.05.2026.**

By Orders
DGM & Zonal Manager
UCO Bank Zonal Office Bhopal

