


1. All installations shall comply with the requirements of the Indian Electricity Rules, 1956, as amended from time to time and as per relevant clauses of National Electrical Code, 1985.
2. Installations shall conform in all respects to Indian Standard Code of Practice for electrical wiring installation IS. 732-1963 and IS 2274-1963.
3. It shall also be in conformity with the regulations and requirements of the Local Electric Supply Authority.
4. Wherever these specifications call for a higher standard of materials and/or workmanship than those required by any of the above regulations, this specification shall take precedence over the said regulations and workmanship not covered by the above shall conform to the Indian standards, unless otherwise called for.
5. Equipment shall be given tropical and fungicidal treatment as per IS - 3202.



SL NO	SYMBOL	DESCRIPTION
1		LIGHT CONTROL SWITCH BOARD WITH /WITHOUT 6A SWITCH SOCKET OUTLET ON BOARD (Modular Type)
2		16A SWITCH SOCKET OUTLET( NORMAL/UPS) (Modular)
3		36W (2x18W) FC MOUNTING LED LIGHT FITTINGS (Approved make Model PBLM21368)
4		1x22W ENCLOSED LED LIGHT FITTINGS (Approved make Model PBTM08208)
5		1x15-18W LED CEILING/DOWN LIGHT FITTINGS (Approved make Model PDLM26153-158)
6		400MM SWEEP WALL MOUNTING FAN (Crompton/ Orient)
7		225MM SWEEP EXHAUST FAN(EPC (Crompton make)
8		2+12 WAY SPN(1no-40/63A, DP) ISOLATOR INCOMING +8nos 6/10A SP OUTGOINGS- LIGHTING MCB DB
9		4WAY TPN(1no-63A, 4P) ISOLATOR INCOMING +12nos 16/20A SP OUTGOINGS- MCB DB
10		1 TR/ 1.5 TR AC UNIT (SPIT TYPE)
11		TELEPHONE SOCKET OUTLET
12		DOOR CHIME

## FALSE CEILING & LIGHTING DRAWING

title

**PROPOSED LAYOUT**

project	<b>Refurbishing of Proposed Hridaypur Branch at Hridaypur Gram Panchayat, PO: Sutia, Dist: Nadia, West Bengal</b>
---------	---

**The Senior Manager**  
UCO Bank, Zonal Office Durgapur

**Aloke Roy**  
Garia

**SRIJANI**  
a comprehensive architectural solution

**studio:** 131 Arya Vidyalaya Road Kolkata 700 078 INDIA  
**tel:** +91.33.24054935 | **fax:** +91.33.24054935  
**email:** [architecture@srijani.com](mailto:architecture@srijani.com) | **website:** [www.srijani.com](http://www.srijani.com)

job no 2204-Com-UCB-Hridyapur(Nadia)	sheet no 2204-AD-E-01
dealt by AR	date 21 December 2022
checked by PM	scale 1:50
verified by AM	revision no 0